



TOWN OF
HOLLIS
NEW HAMPSHIRE

Town of Hollis Board of Health *Office of the Selectmen*

Water Supply Regulations – Private Wells Water Quality Standards

The Board of Health of the Town of Hollis, NH, acting under RSA 147.1, has, in the interest of and for the preservation of the public health and to provide adequate safe wells, duly made and adopted, on December 2, 2002 the following potable water quality standards:

Water System:

All wells to be used as a potable water supply source shall be designed, constructed, and satisfy all requirements set forth in pertinent State of New Hampshire, Department of Environmental Services, Water Resource Management Bureau regulations as they exist, may be established, or may be amended in the future.

Water Quality Standards:

Well testing shall be done by a NH Certified Well Testing Laboratory, which shall actually collect the water sample(s) to be tested, this test is for informational purposes only and shall include, but not limited to, the following:

Test	EPA Maximum	Units of Measure
Total Coliform(P)	0	Counts per 100 ml
Fecal Coliform	0	Counts per 100 ml
Calcium	No Limit	mg/L
Copper (S)	1.3	mg/L
Magnesium	No Limit	mg/L
Nitrate (P)	10	mg/L
pH (S)	6.5 – 8.5	SU
Iron (S)	0.3	mg/L
Manganese(S)	0.05	mg/L
Sodium	"250	mg/L
Chloride (S)	250	mg/L
Color (S)	15	CPU
Fluoride	4	mg/L
Hardness	No Limit	mg/L
Sulphates (S)	250	mg/L
Turbidity	Not Spec.	NTU
Lead	0.015	mg/L
Radon	"2000	pCi/L
Arsenic	0.01	mg/L

(P) = Primary EPA Standards, (S) = Secondary EPA Standards




TOWN OF
HOLLIS
NEW HAMPSHIRE


Certificate of Occupancy:


No Certificates of Occupancy will be issued until the water source has been tested and results submitted to the Hollis Health Department. The water sample testing and water quality results shall be performed and submitted no earlier than 60 days prior to issuing the Certificate of Occupancy.

BOARD OF SELECTMEN, TOWN OF HOLLIS


Donald Ryder, Chairman


Richard Walker, Vice Chairman


Vahrij Manoukian


Thomas Jambard


Lorin Rydstrom